
V3IS00647-010





Mod. RX7-5A

I - 32032 Feltre (BL) • Via Camp Lonc, 16

Tel +39 0439 80638 • Fax +39 0439 80619 e-mail: info@vemer.it - web site: www.vemer.it







# **User Manual** REMOTE ACTUATOR MODEL RX7-5A

Read all the instructions carefully

- The remote actuator **RX7-5A** is an electronic independently mounted automatic control for heating and air conditioning applications, designed for comunications in the range of Verner thermostat and programmable thermostat via radiofrequency or via bus. It provides a type IB actions and it is designed for household and similar use with overvoltage
- category III and pollution level 2 (EN 60730-1).

# SAFETY WARNINGS

During product installation and operation, the following safety instructions should be

- 1) The instrument should be installed by qualified personnel
- 3) Do not power or connect the instrument if any part of it is damaged
- Follow the connection diagrams descripted on this manual and over the instrument
- switch and a protective device against over-currents. The instrument must be installed and activated in compliance with current electric systems
- 7) After installation, inaccessibility to the connection terminals without appropriate tools must

Code	Model	Description	
VE443800	RX7-5A	Remote actuator	

### TECHNICAL SPECIFICATIONS

- Outputs:
  - 6 relays with normally open contact 5A/250 V AC for zone valvs activation
  - 1 relays with normally open contact 5A/250 V AC for pump activation

- Terminals for cable with 6 mm2 maximum section
- Operating temperature: 0°C ÷ 50°C
- Storage temperature: -10°C ÷ 65°C
- Operating humidity: 20 ÷ 90% non condensing
- Protection degree: IP20 (IP40 when correctly installed in an electrical panel)
- Insulation: reinforced among frontal and all other terminals

- ① GREEN LED: operation function (power supply)
- RED LEDS: relay status (output 1 6)
- YELLOW LED: relay status (output 7)
- SET KEY for programmation and reset channel
- TRIMMER to set the relay 7 switching delay

respected:

- Before touching the terminals, make sure there is no power supply to the electric wires
- The electrical system of the building in which the instrument is to be installed should have a


Code	Model	Description	
VE443800	RX7-5A	Remote actuator	

- Power supply: 230 VAC (-15%/+10%) 50/60 Hz
- Absorption: 3 W (8 VA)
- - terminals to connect an external antenna (included in the box)
- serial port for Athena network connection (RS-485)
- Relay 7 switchting delay setting from 3 second to 5 minutes by trimmer

- Enclosure: 4 module DIN

# **OPERATION**

# Network example



- Living room probe: built into Athena programmable thermostat
- Bedroom probe: remote, connection to Athena via bus 485
- Bathroom probe: built into Klio
- Entrance probe: remote, connection to Athena via bus 485
- Kitchen probe: built into Mithos RF

The air-conditioning equipment is controlled by means of a remote actuator (RX7-5A) via RF and/or 485 bus.

### **OPERATION**

- In starting phase, the red leds and yellow led flashes twice for some seconds (switching onsequence).
- At the end of the switching on-sequence, the green LED signal normal device operation and the red LEDs relay status (light on = relay ON). If at least one of the zone valve output (relay 1 ... relay 6) is turn on, automatically is also activated the pump output (relay 7), with a delay that can be set from 3 seconds to 5 minutes by trimmer on the front of the instrument.
- The remote control (relay commutation ON/OFF) request from thermostats and programmable thermostats take place only after channel setting-up.
- The radio connection break down for more than 15 minutes between the transmitter and the receiver disconnects the relay/relays and the red LED/LEDs lightened. Restore of operations is automatic.

### Channel setting-up

- During normal operation, press the SET key-button for almost three seconds to enter in modality-configuration. Green LED switch-off, red LED flash. Press the SET key-button to select the output relay.
- The instrument keep on modality-configuration for a maximum of 60 seconds within the actuator should receive a string configuration (see thermostats or programmable thermostats instructions for string start-up modality).
- On receipt of string, channel is setted-up and the actuator is on standard functioning.
- For re-setting up, repeating the procedure.
- To reset channel setting-up, plug into configuration modality with SET button, then push the same one for three seconds and wait for green led switching on.

## **SERIAL OUTPUT**

RX7-5A features an insulated serial output RS 485 for communication. It is possible to connect up to 31 instruments up to a maximum distance of 40 m.

Note: It is possible to connect a remote actuator with different programmable thermostats Athena. In this case it is necessary to configure different zones for each Athena. Exemple: 2 Athena are connected with a remote actuator: if Z1 is selected in the first Athena, then Z2, Z3 or Z4 must be selected in the second Athena.

## STANDARDS REFERENCE

Conformity to the EU directives:

2006/95/EC (Low Voltage) 2004/108/EC (Electromagnetic Compatibility)

is declared with reference to the following harmonized standard:

# ■ EN 60730-1

EN 301 489-1/3 and EN 300 220-1/2